

## Facility Summary in JEFFERSON County in the City of BOULDER

**Location:** TOWN PUMP INC BOULDER  
703 N MAIN  
BOULDER, MT 59632 JEFFERSON

**Sys Fac ID:** 22-08673

**Last Inspected On:** 3/25/2013

**Operating Permit Renewal Date:** 6/29/2016

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	27	1/1/1989	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4477</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/16/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		9/26/2006			
2	26	5/10/1989	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>4478</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/16/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
9,000		9/26/2006			
3	38	5/10/1977	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>2486</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		3/16/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		9/26/2006			
4	38	5/10/1977	Bare Steel	Flexible Plastic	Ball Float Valve
<b>2487</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		3/16/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		9/26/2006			

## Facility Summary in JEFFERSON County in the City of BOULDER

**Location:** TOWN PUMP INC BOULDER  
703 N MAIN  
BOULDER, MT 59632 JEFFERSON

**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 22-08673  
**Last Inspected On:** 3/25/2013  
**Operating Permit Renewal Date:** 6/29/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	38	5/10/1977	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
<b>2485</b>			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		3/16/2013	Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		9/26/2006			
6	14	4/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4479</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/14/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		9/26/2006			
7	14	4/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4480</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/14/2010	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		9/26/2006			

## Facility Summary in JEFFERSON County in the City of BOULDER

**Location:** HARLOWS SCHOOL BUS SERVICE INC BOULDER  
101 N MAIN ST  
BOULDER, MT 59632 JEFFERSON

**Sys Fac ID:** 22-12378

**Last Inspected On:** 1/13/2015

**Operating Permit Renewal Date:**

**Contact:** Mike Benson, (406) 225-3344

**Owners/Operators:** Harlows School Bus Service Inc, Owner (406)-293-8845 30772 US HIGHWAY 2  
LIBBY MT 59923-3130

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	24	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>2710</b>			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000					
7	24	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>2711</b>			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000					

## Facility Summary in JEFFERSON County in the City of CARDWELL

**Location:** CARDWELL STORE LLC  
770 MT HIGHWAY 2 E  
CARDWELL, MT 59721 JEFFERSON

**Contact:** Kipp Huckaba, (406) 287-5092

**Sys Fac ID:** 22-13424  
**Last Inspected On:** 4/15/2014  
**Operating Permit Renewal Date:** 9/3/2017

**Owners/Operators:** Kipp Huckaba, Owner (406)-287-5092 PO BOX 55  
CARDWELL MT 59721-0055

Kipp Huckaba, UST Class A Operator  
Kipp Huckaba, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3193</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
9,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	21	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3194</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	21	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3195</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
4	21	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>3196</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in JEFFERSON County in the City of CLANCY

**Location:** CLANCY STORE UST  
10 E CLANCY ST  
CLANCY, MT 59634 JEFFERSON

**Sys Fac ID:** 22-02898

**Last Inspected On:** 10/10/2012

**Operating Permit Renewal Date:**

**Contact:** Melva Fowler, (406) 933-8278

**Owners/Operators:** EMMK LLC, Owner

(406)-442-4804

PO BOX 316  
CLANCY MT 59634-0316

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	31	4/26/1984	Bare Steel	Steel	High Level Alarm
<b>3534</b>			Impressed Current	None	Yes
Temporarily Out of Use		5/10/2003	Not Required	Safe Suction	Impressed Current
Gasoline		10/10/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000					
3	22	4/10/1993	Bare Steel	Steel	High Level Alarm
<b>4647</b>			Impressed Current	None	Yes
Temporarily Out of Use		5/10/2003	Not Required	Safe Suction	Impressed Current
Gasoline		10/10/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000					

## Facility Summary in JEFFERSON County in the City of CLANCY

**Location:** ASH GROVE CEMENT WEST INC  
100 STATE HIGHWAY 518  
CLANCY, MT 59634 JEFFERSON

**Sys Fac ID:** 22-02928

**Last Inspected On:** 9/24/2015

**Operating Permit Renewal Date:** 12/8/2018

**Contact:** Joseph Scheeler, (406) 442-8855

**Owners/Operators:** Ash Grove Cement Company, Owner (406)-442-8855 100 STATE HIGHWAY 518  
CLANCY MT 59634-9665

Jeff Briggs, UST Class A Operator

Jeff Briggs, UST Class B Operator

Robert Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	25	3/30/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>392</b>			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/15/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		6/14/2012	TLS-350/Gilbarco EMC , Veeder Root		
5	25	3/30/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
<b>393</b>			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/15/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		6/14/2012	TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in JEFFERSON County in the City of MONTANA CITY

**Location:** MONTANA CITY STORE LLC  
1 JACKSON CREEK RD  
MONTANA CITY, MT 59634 JEFFERSON

**Sys Fac ID:** 22-01822

**Last Inspected On:** 2/21/2013

**Operating Permit Renewal Date:** 6/1/2016

**Contact:** Charles Hunter, (406) 443-0150

**Owners/Operators:** Montana City Properties Inc, Owner

(406)-443-0150

ATTN CHARLES L HUNTER  
1 JACKSON CREEK RD  
CLANCY MT 59634-9714

Jennifer Graybeal, UST Class A Operator

Ed Field, UST Class B Operator

Jennifer Graybeal, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	27	7/1/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1668</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/5/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000					
6	27	7/1/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1669</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/5/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
7	27	7/1/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>1670</b>			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/5/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					

## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** THE CORNER STORE WHITEHALL  
203 W LEGION AVE  
WHITEHALL, MT 59759 JEFFERSON

**Sys Fac ID:** 22-00980

**Last Inspected On:** 6/25/2013

**Operating Permit Renewal Date:** 10/9/2016

**Contact:** Dave Sutey, (406) 287-3746

**Owners/Operators:** Sutey Oil Co Inc, Owner

(406)-494-2305

2000 HOLMES AVE  
BUTTE MT 59701-3553

Timothy Mulligan, UST Class A Operator

Timothy Mulligan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	22	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>529</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/4/2013			
2	22	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>527</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/4/2013			
3	22	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
<b>528</b>			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/4/2013			



## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** TOWN PUMP INC WHITEHALL  
417 N WHITEHALL ST  
WHITEHALL, MT 59759 JEFFERSON

**Sys Fac ID:** 22-03645

**Last Inspected On:** 7/1/2015

**Operating Permit Renewal Date:** 10/14/2018

**Contact:** Trent Biggers, (406) 497-6700

**Owners/Operators:** Town Pump of Whitehall Inc, Owner (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, Operator (406)-497-6700 PO BOX 6000  
BUTTE MT 59702-6000  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	48	1/1/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2476</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	48	1/1/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2477</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	38	1/1/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2478</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, MLLD Line Tightness Testing, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** TOWN PUMP INC WHITEHALL  
417 N WHITEHALL ST  
WHITEHALL, MT 59759 JEFFERSON

**Contact:** Trent Biggers, (406) 497-6700

**Sys Fac ID:** 22-03645  
**Last Inspected On:** 7/1/2015  
**Operating Permit Renewal Date:** 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	40	1/1/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2479</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, MLLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	38	1/1/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2480</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	38	1/1/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2481</b>			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** TOWN PUMP INC WHITEHALL  
417 N WHITEHALL ST  
WHITEHALL, MT 59759 JEFFERSON

**Sys Fac ID:** 22-03645  
**Last Inspected On:** 7/1/2015  
**Operating Permit Renewal Date:** 10/14/2018

**Contact:** Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	30	1/1/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2482</b>			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
8	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
<b>2483</b>			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
9	29	1/1/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
<b>2484</b>			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** TOWN PUMP INC WHITEHALL  
417 N WHITEHALL ST  
WHITEHALL, MT 59759 JEFFERSON

**Sys Fac ID:** 22-03645  
**Last Inspected On:** 7/1/2015  
**Operating Permit Renewal Date:** 10/14/2018

**Contact:** Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
<b>4198</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
11	15	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, Not Applicable
<b>4199</b>			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** GOLDEN SUNLIGHT MINES INC UST  
453 MT HIGHWAY 2 E  
WHITEHALL, MT 59759 JEFFERSON

**Sys Fac ID:** 22-04689  
**Last Inspected On:** 8/20/2015  
**Operating Permit Renewal Date:** 12/17/2018

**Contact:** Debbie Johnson-Horne, (406) 287-2016

**Owners/Operators:** Golden Sunlight Mines Inc, Owner (406)-287-3257 453 MT HIGHWAY 2 E  
WHITEHALL MT 59759-8637

Rick Henderson, UST Class A Operator  
Debby Horne, UST Class A Operator  
Darrell Scharf, UST Class A Operator  
Seth Slatter, UST Class B Operator  
George Clements, UST Class B Global Operator  
John C Clements, UST Class B Global Operator  
Joseph Dillon, UST Class B Global Operator  
Dave Lawrence, UST Class B Global Operator  
Travis Nielsen, UST Class B Global Operator  
Ray Panisko, UST Class B Global Operator  
John Perigo, UST Class B Global Operator  
Donald M Pippin Jr, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	07	6/12/2008	Unknown	Other	
<b>5218</b>	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
1,000			LDE Series , Pneumercator		Yes
7	07	6/12/2008	Unknown	Flexible Plastic	
<b>5219</b>	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
1,000			LDE Series , Pneumercator		Yes

## Facility Summary in JEFFERSON County in the City of WHITEHALL

**Location:** GOLDEN SUNLIGHT MINES INC UST  
453 MT HIGHWAY 2 E  
WHITEHALL, MT 59759      JEFFERSON

**Sys Fac ID:** 22-04689  
**Last Inspected On:** 8/20/2015  
**Operating Permit Renewal Date:** 12/17/2018

**Contact:** Debbie Johnson-Horne, (406) 287-2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	06	6/12/2009	Unknown	Flexible Plastic	
<b>5220</b>	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
1,500			LDE Series , Pneumercator		Yes
9	07	6/12/2008	Unknown	Steel - Terminal Piping	
<b>5221</b>	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
2,000			LDE Series , Pneumercator		Yes
10	07	6/12/2008	Unknown	Flexible Plastic	
<b>5222</b>	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Oil Substance			Deferred	Continuous Interstitial Monitor	
2,000			LDE Series , Pneumercator		Yes